5

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
PIMPRI – 411 018

No. E/Health/5/WS/122/2025 Date:- 07/08/2026

"Safe drinking water and sanitary condition certificate"

It is certified that an inspection team headed by "Health Department" of Pimpri Chinchwad Municipal Corporation, Pimpri-411018, from Deputy Commissioner, Health Department, Pimpri Chinchwad Municipal Corporation, Pimpri-411018, inspected "**Lakshadeep Inernational School**", situated at Savantnagar Bhosari, checked the water test reports, submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building and the campus as per the norms prescribed by the State government norms.

The above certificate is valid for a period of one year from the date of issue..

स्थापना
११-१०-१९८२

Zonal Officer
E Zone Office
Pimpri Chinchwad Muncipal Corporation

Pimpri Chinchwad Municipal Corporation
Pimpri , Pune – 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

NO – ws/lab/350/2026

Date – 30/06/2026

To

The Principal,

Lakshadeep International School,

Sr No. 205/1, Bhosari.

Subject: Water sample Potability Certificate.

Drinking water sample provided by Lakshadeep International School, Sr No. 205/1, Bhosari on Date: 25/06/2026 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /333/2026 dated 27/06/2026 & ws /lab /341/2026 dated 27/06/2026 the water Samples are safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory

CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

Water Treatment Plant
Laboratory Nigdi

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

REPORT OF CHEMICAL EXAMINATION OF WATER

NAME - Lakshadeep International School

ADDRESS - Sr.No. 205/1, Bhosari.

SOURCE - PCMC Water.

No-WS/LAB/ 333 /2026.

Date - 27 / 06 /2026.

Date of Receipt - 25/ 06 /2026.

Date of Examination - 25 / 06 /2026.

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	2.54 NTU.		
2	pH	6.5 to 8.5	7.56.		
3	Total Hardness (as CaCO3)	200 mg/lit	88 mg/lit.		
4	Chloride	250 mg/lit	12 mg/lit.		
5	Calcium	75 mg/lit	14.42 mg/lit.		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

CHIEF CHEMIST
WATER TREATMENT PLANT, NIGDI, PCMC

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

REPORT OF BACTERIOLOGIAL EXAMINATION OF WATER

No-WS/LAB/341 /2026.

Date - 27 / 06 /2026.

NAME - Lakshadeep International School DATE OF EXAMINATION - 26 /06/2026.

ADDRESS - Sr. No. 205/1, Bhosari.

SOURCE - PCMC Water.

SR.NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coli	
1	Water Sample	0.4 ppm	0/100ml	-	Potable.
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					

CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY